

# Warranty & life time statement

**aquatherm orange system**

underfloor heating

**aquatherm green pipe**

pipe system

**aquatherm lilac pipe**

pipe system for recycled  
reclaimed water

**aquatherm blue pipe**

pressure pipe system for  
chilled and hot applications

**aquatherm red pipe**

sprinkler pipe system

aquatherm GmbH manufacture all pipes and fittings in accordance with the German DIN confirming a 50 year guarantee of service life in accordance with the permissible working pressure / temperature of their technical product manuals. Within the scope of this, aquatherm will supply replacement material pipe and fittings if damages are traceable to materials faults and defects.

## Liability Warranty

furthermore within the scope of the aquatherm GmbH gives a 10 year guarantee which compensates for material damage to third persons, for investigation, removal, replacement, acceptance, dismounting or laying bare of all defective goods.

aquatherm GmbH guarantee is conditional on:

- The fusion of joining of pipe and fittings using only aquatherm GmbH welding tools and devices.
- Installation of pipe and fittings are certified aquatherm installers and adherence to aquatherm GmbH technical rules and guidelines for correct installation principles.

## Limits of Liability

- **For bodily injury** 15.000.000 Euro
- **For property damage** 15.000.000 Euro  
[per occurrence]

Installation Address: .....

Description of Installation: .....

Name of Plumber: .....

Signature: .....

Date of Completion: .....

Reg. Installer Number: .....

This warranty must be fully completed, signed and returned with the completed test sheet within three months of the completion of the project installation to the New Zealand Agent.

aquatherm® NZ limited, P.O. Box 99 393, Newmarket, Auckland, New Zealand. Phone 09 5707204, Fax 09 570 7206

# aquatherm NZ Test record - aquatherm green pipe installation principles

| Description of the Installation  |                         |
|--|-------------------------|
| Street Address   |                         |
| Suburb   |                         |
| City   |                         |
| Type of Installation   | Domestic                |
|  | Commercial              |
| Type of Pipe   | aquatherm green pipe    |
|  | aquatherm blue pipe     |
|  | aquatherm lilac pipe    |
|  | aquatherm red pipe      |
|  | aquatherm grey pipe     |
|  | aquatherm orange system |
| Time testing Started   |                         |
| Time testing finished  |                         |
| Test period (minutes)  |                         |
| Client:  |                         |
| Contractor:  |                         |
| Installers #:  | Date:                   |
| Declaration:   |                         |
| I declare that I have installed the above product in accordance with aquatherm specifications with no branding mix |                         |
| Signature:   |                         |

**aquatherm® NZ** limited must receive this information within 3 months of the installation for the warranty to be valid. Please consult with your local area Council as they may require a copy of the test results for the records.

Preliminary Test  
[Testing procedure NZ January 2001]  
Test pressure - 20 bar:

1. Test pressure 20 bar 10 minutes.
2. Unpressurise for 1 minute.
3. Test pressure 20 bar 5 minutes.
4. Unpressurise for 1 minute.
5. Test pressure 20 bar for 5 minutes.
6. Unpressurise.

## WARNING

**It is imperative to have movement during test period. Tight clips or damaged pipes in frame work will result in an incomplete test which will result in the warranty being invalid.**

Result preliminary test:

The test is to be conducted as a continuous test as 20 bar with the five steps noted above.

The system **MUST** be pressurised **THREE TIMES** with a minimum rest of one minute between re-pressurising.

If leaking occurs, please replace the part and re-start the testing procedure.

The test is complete and acceptable when the above has been undertaken and no leaks are present.

Finally, complete all parts for the test sheet and return a copy to:

**aquatherm NZ Limited**

P.O. Box 99393,  
Newmarket,  
Auckland 1149